

Approved wastewater products in South Australia

Secondary Treatment Systems

Manufacturer	Model name	EP and treatment capacity	Description, servicing frequency, and recommended desludge frequency at maximum design EP use	DHW Approval No. & expiry	AS 1546.3:2017 Certification No. & expiry
Arris Pty Ltd Urrbrae, SA info@arris.com.au	ABSORBS™ Sand Filter	Minimum 8 EP, may be scaled up using a maximum treatment capacity of: 40 L/m ² /d 18.5g BOD ₅ /m ² /d	Pressure-dosed lined sand filter that can be installed as a lined system with irrigation, or an unlined system. Minimum surface area 30m ² . Requires a septic tank and pump sump on inlet side. For lined system, an irrigation pump sump with chlorine dosing unit is required on the outlet side. For unlined system, basal area sized using DLR for secondary treated effluent from Table L1 of AS/NZS 1547.	WWP-20106/2 28 October 2026	SMK41128 28 October 2026
Alphatreat Pty Ltd Brendale, QLD info@wastewaterequiment.com.au	Alpha Treat ATDP10AS	10 EP 1,500L/d 700g BOD ₅ /d	Two-tank, polyethylene, both vertical orientation. Tank 1 is a septic tank with baffle. Tank 2 contains aeration chambers, clarification chambers, disinfection chamber, and irrigation chamber. Servicing frequency: 3 monthly Desludge frequency: 4 years or as required	WWP-20130 3 November 2027	4283-2786-01 3 November 2027

Manufacturer	Model name	EP and treatment capacity	Description, servicing frequency, and recommended desludge frequency at maximum design EP use	DHW Approval No. & expiry	AS 1546.3:2017 Certification No. & expiry
Eco-Septic Pty Ltd Warragamba, NSW sales@ecoseptic.com.au BioCycle Sheidow Park, SA sales@biocycle.com.au	Eco Pro 1500 <i>or</i> BioCycle Pro 1500	10 EP 1,500L/d 700g BOD ₅ /d	Single tank, concrete, vertical orientation. Contains a primary settlement chamber, aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.2 years or as required	WWP-20056/1 3 July 2025	4994-3300-01 3 November 2024
	Eco Pro 1500 <i>or</i> BioCycle Pro 1500	10 EP 1,500L/d 700g BOD ₅ /d	Single tank, polyethylene, vertical orientation. Contains a primary settlement chamber, aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.2 years or as required	WWP-20056/1 3 July 2025	4994-3300-01 3 November 2024
	Maxi 5000 <i>or</i> BioCycle Maxi 5000	33.3 EP 5,000L/d 1,665g BOD ₅ /d	Two-tank, concrete, both vertical orientation. Tank 1 is a septic tank with baffle. Tank 2 contains aeration chambers, clarification chambers, disinfection chamber, and irrigation chamber. Servicing frequency: 3 monthly Desludge frequency: 4.8 years or as required	WWP-20076/1 3 July 2025	4993-3300-01 29 June 2026
	Poly Maxi 5000 <i>or</i> BioCycle Maxi 5000	33.3 EP 5,000L/d 1,665g BOD ₅ /d	Two-tank, polyethylene, both vertical orientation. Tank 1 is a septic tank with baffle. Tank 2 contains aeration chambers, clarification chambers, disinfection chamber, and irrigation chamber. Servicing frequency: 3 monthly Desludge frequency: 4.8 years or as required	WWP-20076/1 3 July 2025	4993-3300-01 29 June 2026

Manufacturer	Model name	EP and treatment capacity	Description, servicing frequency, and recommended desludge frequency at maximum design EP use	DHW Approval No. & expiry	AS 1546.3:2017 Certification No. & expiry
<p>Eljen Corporation Windsor, CT, USA</p> <p><i>Distributed by</i></p> <p>Eljen Pacific Devonport, TAS</p> <p>paul@eljenpacific.com</p>	Eljen Geotextile Sand Filter (GSF) A42	<p>Minimum 8 EP</p> <p>System may be scaled up, using a maximum treatment capacity of:</p> <ul style="list-style-type: none"> - 80 L/d/media module - 37g BOD₅/d/media module 	<p>A geotextile sand filter (minimum surface area 17.5m²). Requires a septic tank (minimum 4,000L) with bristle-type outlet filter. Dose loading via gravity using a SeptiSurge[®] dynamic fluid manifold, or pump dosing via pump sump (minimum 1,000L). GSF consists of a minimum of 15 media modules, covered with geotextile fabric, surrounded by specified sand layer. Unit may be lined or unlined. Basal area for unlined system sized using DLR for secondary treated effluent from Table L1 of AS/NZS 1547.</p> <p>Servicing frequency: N/A Desludge frequency (septic tank): 4 years or as required</p>	<p>WWP-20126 (pumped)</p> <p>WWP-20161 (gravity)</p> <p>16 July 2026</p>	<p>SMK41040</p> <p>16 July 2026</p>
<p>Eloy Water Australia Pty Ltd Palm Beach, QLD</p> <p>info@eloywater.com.au</p>	Oxyfix AU 8 EP	<p>8 EP</p> <p>1,200L/d 560g BOD₅/d</p>	<p>Single tank, concrete, vertical orientation. Contains a primary settlement chamber, a biological reactor chamber, a clarification chamber, and a pump/disinfection chamber.</p> <p>Servicing frequency: 4 monthly (annually if irrigation is subsurface) Desludge frequency: 9 years or as required</p>	<p>WWP-20123</p> <p>30 March 2025</p>	<p>3865-2928-03</p> <p>21 June 2027</p>
<p>Everhard Industries Geebung, QLD</p> <p>info@everhard.com.au</p>	Aqua Advanced	<p>8 EP</p> <p>1,200L/d 560g BOD₅/d</p>	<p>Single tank, concrete, vertical orientation. Contains a primary settlement chamber, aeration chamber, clarification chamber, and pump/disinfection chamber.</p> <p>Servicing frequency: 3 monthly Desludge frequency: 3.3 years or as required</p>	<p>WWP-20074</p> <p>28 September 2025</p>	<p>632</p> <p>28 September 2025</p>

Manufacturer	Model name	EP and treatment capacity	Description, servicing frequency, and recommended desludge frequency at maximum design EP use	DHW Approval No. & expiry	AS 1546.3:2017 Certification No. & expiry
Everhard Industries Geebung, QLD info@everhard.com.au	Aqua Advanced	8 EP 1,200L/d 560g BOD ₅ /d	Single tank, polyethylene, vertical orientation. Contains a primary settlement chamber, aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.3 years or as required	WWP-20074 28 September 2025	632 28 September 2025
FujiClean Australia Helensvale, QLD info@fujiclean.com.au	ACE1200	8 EP 1,200L/d 560g BOD ₅ /d	Single tank, fibre-reinforced plastic, horizontal orientation. Contains a primary settlement chamber, anaerobic filtration chamber, aerobic filtration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 5 years or as required	WWP-20162 15 March 2029	5627-3568-01 15 March 2029
	ACE3000	20 EP 3,000L/d 1,400g BOD ₅ /d	Single tank, fibre-reinforced plastic, horizontal orientation. Contains a primary settlement chamber, anaerobic filtration chamber, aerobic filtration chamber, clarification chamber, and disinfection chamber. Requires a third party pump chamber for irrigation. Servicing frequency: 3 monthly Desludge frequency: 2.3 years or as required	WWP-20107 15 August 2026	649 15 August 2026
Global Rotomoulding Pty Ltd Helidon Spa, QLD	UBI Aqua Mk II	8 EP 1,200L/d 560g BOD ₅ /d	Single tank, polyethylene, vertical orientation. Contains a primary settlement chamber, aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.6 years or as required	WWP-20127 10 May 2027	SMK40298 10 May 2027

Manufacturer	Model name	EP and treatment capacity	Description, servicing frequency, and recommended desludge frequency at maximum design EP use	DHW Approval No. & expiry	AS 1546.3:2017 Certification No. & expiry
Global Rotomoulding Pty Ltd Helidon Spa, QLD	UBI Aqua Aerated Wet Cell	10 EP 1,500L/d 700g BOD ₅ /d	Reed bed treatment system consisting of a 6,000L septic tank, two 'wet cell' reed beds in series, a 1,000L pump sump connected to an indexing valve, and a 1,000L disinfection/pump chamber. Servicing frequency: 3 monthly Desludge frequency: 8 years or as required	WWP-20150 10 May 2027	SMK40298 10 May 2027
Nodiff Group Pty Ltd Chinchilla, QLD admin@positreat.com.au	Positreat PTLX 1.5-00	10 EP 1,500L/d 700g BOD ₅ /d	Transportable treatment unit consisting of a Taylex Poly ABS1500 unit on a skid mount. Installed on ground and requires macerator pump stations to be installed prior to unit. Servicing frequency: 3 monthly Desludge frequency: 3.2 years or as required	WWP-20116 19 August 2025	40/22 19 August 2025
	Positreat PTLX 3-00	20 EP 3,000L/d 1,400g BOD ₅ /d	Transportable treatment unit consisting of two Taylex Poly ABS1500 units on a skid mount. Installed on ground and requires macerator pump stations to be installed prior to unit. Servicing frequency: 3 monthly Desludge frequency: 3.2 years or as required		
	Positreat PTLX 6-00	40 EP 6,000L/d 2,800g BOD ₅ /d	Transportable treatment unit consisting of four Taylex Poly ABS1500 units on a skid mount, along with grease arrestor and irrigation pump sump. Installed on ground and requires macerator pump stations to be installed prior to unit. Servicing frequency: 3 monthly Desludge frequency: 3.2 years or as required	WWP-20109/1 19 August 2025	

Manufacturer	Model name	EP and treatment capacity	Description, servicing frequency, and recommended desludge frequency at maximum design EP use	DHW Approval No. & expiry	AS 1546.3:2017 Certification No. & expiry
Property Werx Pty Ltd Wauchope, NSW info@wormsmart.com.au	Wormsmart WSP1500PF	10EP 1,500L/d 700g BOD ₅ /d	Two tank biological filter treatment system. Contains a 3kL primary treatment tank with worms, media and pump, an above-ground sludge basket with filter, and a 3kL secondary treatment tank with media, filter and pump. An additional disinfection chamber can be installed for surface irrigation. Servicing frequency: 3 monthly by a WormSmart accredited service agent Desludge frequency: 4.4 years or as required	WWP-20138 25 January 2028	2536-2921-01 25 January 2028
Ri-Industries Angle Park, SA sales@ri-industries.com.au	Ri-Treat EP10	10 EP 1,500L/d 700g BOD ₅ /d	Single tank, concrete, vertical orientation. Contains a primary settlement chamber, aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 6 years or as required	WWP-20078 13 October 2025	SMK20560 13 October 2025
	Ri-Treat EP30	33EP 5,000L/d 2,310g BOD ₅ /d	Three-tank, concrete, all vertical orientation. Contains an 8kL septic tank, an 8kL aeration tank, and an 8kL tank with aeration, settlement and pump/disinfection chambers. Servicing frequency: 3 monthly Desludge frequency: 3.8 years or as required	WWP-20105 13 October 2025	
Suncoast Waste Water Management Kunda Park, QLD info@ozzicleen.com	Ozzi Kleen RP10	10 EP 1,500L/d 700g BOD ₅ /d	Single tank, polyethylene, vertical orientation. Contains a primary settlement/aeration chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 1.9 years or as required	WWP-20103 22 July 2027	SMK02608 22 July 2027

Manufacturer	Model name	EP and treatment capacity	Description, servicing frequency, and recommended desludge frequency at maximum design EP use	DHW Approval No. & expiry	AS 1546.3:2017 Certification No. & expiry
Suncoast Waste Water Management Kunda Park, QLD info@ozzicleen.com	Ozzi Kleen RP10S	10 EP 1,500L/d 700g BOD ₅ /d	Single tank, polyethylene, vertical orientation. Contains a primary settlement/aeration chamber, and pump/disinfection chamber, and alum dosing system. Servicing frequency: 3 monthly Desludge frequency: 2.8 years or as required	WWP-20103 22 July 2027	SMK02608 22 July 2027
	Ozzi Kleen RP10S+	10 EP 1,500L/d 700g BOD ₅ /d	Single tank, polyethylene, vertical orientation. Contains a primary settlement/aeration chamber, and pump/disinfection chamber, and alum dosing system. Servicing frequency: 3 monthly Desludge frequency: 0.9 years or as required		
	Ozzi Kleen RP10A+	10 EP 1,500L/d 700g BOD ₅ /d	Single tank, polyethylene, vertical orientation. Contains a primary settlement/aeration chamber, pump/disinfection chamber, and alum dosing system. Servicing frequency: 3 monthly Desludge frequency: 2.9 years or as required		
	Ozzi Kleen SK20A & SK20G	20 EP 4,000L/d 1,400g BOD ₅ /d	Transportable treatment unit consisting of a manual bar screen, inflow balance tank, and two Ozzi Kleen RP10 units and on a skid mount. The SK20G also contains a grease trap. To be installed on ground, requiring a pump station with proprietary controller prior to unit. Servicing frequency: 3 monthly Desludge frequency: 1.9 years or as required	WWP-20092 22 July 2027	

Manufacturer	Model name	EP and treatment capacity	Description, servicing frequency, and recommended desludge frequency at maximum design EP use	DHW Approval No. & expiry	AS 1546.3:2017 Certification No. & expiry
Supertreat Systems Pty Ltd South Nowra NSW supertreatsystems@gmail.com	Super-Treat ST10P	10 EP 1,500L/d 700g BOD ₅ /d	Two-tank, Polypropylene, vertical orientation. Tank 1 consists of a septic tank with internal baffle wall. Tank 2 contains aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.1 years or as required	WWP-20129 5 December 2026	SMKH20616 5 December 2026
	Super-Treat ST10C	10 EP 1,500L/d 700g BOD ₅ /d	Two-tank, Concrete, vertical orientation. Tank 1 consists of a septic tank with internal baffle wall. Tank 2 contains aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.1 years or as required		
Taylex Australia Pty Ltd Ormeau, QLD info@taylex.com.au	Poly ABS1500	10 EP 1,500L/d 700g BOD ₅ /d	Single tank, polyethylene, vertical orientation. Contains a primary settlement chamber, aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.2 years or as required	WWP-20068 19 August 2025	40/22 19 August 2025
	Concrete ABS1500	10 EP 1,500L/d 700g BOD ₅ /d	Single tank, concrete, vertical orientation. Contains a primary settlement chamber, aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.2 years or as required	WWP-20069 19 August 2025	

Manufacturer	Model name	EP and treatment capacity	Description, servicing frequency, and recommended desludge frequency at maximum design EP use	DHW Approval No. & expiry	AS 1546.3:2017 Certification No. & expiry
Taylex Australia Pty Ltd Ormeau, QLD info@taylex.com.au	Concrete ABS4200	28 EP 4,200L/d 1,960g BOD ₅ /d	Two-tank, concrete, both vertical orientation. Tank 1 contains primary treatment chambers and sedimentation chambers. Tank 2 contains aeration chambers, clarification chambers, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 5.4 years or as required	WWP-20113 18 October 2026	40/26 18 October 2026
	Concrete ABS5000	33.3 EP 5,000L/d 2,331g BOD ₅ /d	Two-tank, concrete, both vertical orientation. Tank 1 contains primary treatment chambers and sedimentation chambers. Tank 2 contains aeration chambers, clarification chambers, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.2 years or as required	WWP-20082 16 December 2025	40/24 16 December 2025
	PABSNR-1350 & ABSNR-1350	9 EP 1,350L/d 630g BOD ₅ /d	Polyethylene or concrete single tank, vertical orientation. Contains a primary pre-treatment chamber, a secondary pre-treatment chamber, an aeration chamber, a sedimentation chamber and a disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.5 years or as required	WWP-20132 29 November 2027	4382-3039-01 (concrete) 4386-3039-01 (poly) 29 November 2027
	PABSNR-1350+P & ABSNR-1350+P	9 EP 1,350L/d 630g BOD ₅ /d	Polyethylene or concrete single tank, vertical orientation. Contains a primary pre-treatment chamber, a secondary pre-treatment chamber, an aeration chamber, a sedimentation chamber and a disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.5 years or as required	WWP-20133 29 November 2027	4383-3039-01 (concrete) 4387-3039-01 (poly) 29 November 2027

Manufacturer	Model name	EP and treatment capacity	Description, servicing frequency, and recommended desludge frequency at maximum design EP use	DHW Approval No. & expiry	AS 1546.3:2017 Certification No. & expiry
Taylex Australia Pty Ltd Ormeau, QLD info@taylex.com.au	PABSNR-2000 & ABSNR-2000	13.3 EP 2,000L/d 931g BOD ₅ /d	Polyethylene or concrete single tank, vertical orientation. Contains a primary pre-treatment chamber, a secondary pre-treatment chamber, an aeration chamber, a sedimentation chamber and a disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 2 years or as required	WWP-20134 29 November 2027	4384-3039-01 (concrete) 4388-3039-01 (poly) 29 November 2027
	PABSNR-2000+P & ABSNR-2000+P	13.3 EP 2,000L/d 931g BOD ₅ /d	Polyethylene or concrete single tank, vertical orientation. Contains a primary pre-treatment chamber, a secondary pre-treatment chamber, an aeration chamber, a sedimentation chamber and a disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 2 years or as required	WWP-20135 29 November 2027	4385-3039-01 (concrete) 4389-3039-01 (poly) 29 November 2027
Wastewater Australia Pty Ltd Rutherford, NSW mail@gardenmaster.com.au	Garden Master Elite	10 EP 1,500L/d 700g BOD ₅ /d	Single tank, concrete, vertical orientation. Contains a primary settlement chamber, aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.2 years or as required	WWP-20077 29 April 2025	562 29 April 2025
	Garden Master Elite FG1500	10 EP 1,500L/d 700g BOD ₅ /d	Single tank, fibreglass, vertical orientation. Contains a primary settlement chamber, aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 3.2 years or as required	WWP-20077 29 April 2025	631 29 April 2025

Manufacturer	Model name	EP and treatment capacity	Description, servicing frequency, and recommended desludge frequency at maximum design EP use	DHW Approval No. & expiry	AS 1546.3:2017 Certification No. & expiry
Wastewater Australia Pty Ltd Rutherford, NSW mail@gardenmaster.com.au	Garden Master Elite 5000	33.3 EP 5,000L/d 2,331g BOD ₅ /d	Two-tank, concrete, both vertical orientation. Tank 1 contains primary treatment chamber. Tank 2 contains aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 4.8 years or as required	WWP-20091 3 July 2025	575 3 July 2025
	Garden Master Elite FG5000	33.3 EP 5,000L/d 2,331g BOD ₅ /d	Two-tank, fibreglass, both vertical orientation. Tank 1 contains primary treatment chamber. Tank 2 contains aeration chamber, clarification chamber, and pump/disinfection chamber. Servicing frequency: 3 monthly Desludge frequency: 4.8 years or as required		

Manufacturer	Model name	EP and treatment capacity	Description, servicing frequency, and recommended desludge frequency at maximum design EP use	DHW Approval No. & expiry	AS 1546.3:2017 Certification No. & expiry
--------------	------------	---------------------------	---	---------------------------	---

More information:

Wastewater Management
 Health Protection and Regulation
 SA Health
 Citi Centre Building
 11 Hindmarsh Square
 Adelaide SA 5000

PO Box 6
 Rundle Mall SA 5000

Tel: (08) 8226 7100

Fax: (08) 8226 7102

Email: healthwastewatermanagement@sa.gov.au

<http://www.sahealth.sa.gov.au/wastewater>

ABN 97 643 356 590

© Department for Health and Wellbeing, Government of South Australia.
 All rights reserved.

Last revised 11 July 2024